




**Water**

# **Guidance Manual for Implementing Total Toxic Organics (TTO) Pretreatment Standards**



#### 4. GUIDANCE FOR THE PREPARATION OF A TOXIC ORGANIC MANAGEMENT PLAN

As previously discussed, one alternative to routine TTO monitoring is the preparation of a toxic organic management plan (TOMP). This option is available to regulated industrial users in the Electroplating, Metal Finishing, and Electrical and Electronic Components (both Phase I and Phase II) categories.

A TOMP must specify the toxic organic compounds used, the method of disposal used (instead of discharge into wastestreams), and procedures for assuring that toxic organics do not routinely spill or leak into wastewater discharged to the POTW. Guidelines for preparation of a TOMP are presented below as four basic steps:

##### Step 1 - Process engineering analysis

A process engineering analysis should be conducted to determine the source and type of toxic organic compounds found in a facility's wastewater discharge, including sources and compounds that could reasonably be expected to enter the wastewater in the event of spills, leaks, etc., based on the type of operations conducted at a particular plant. Such an analysis should be based on the results of one or more analyses of the plant's wastewater for the toxic organic pollutants which are included in the definition of TTO for that industrial category and which can reasonably be expected to be present (see TTO monitoring guidance). The process engineering analysis should include:

- a. An examination of published reports on the specific industry;
- b. A water flow diagram to identify all possible wastewater sources;
- c. A list of raw materials used in the industrial processes, including chemical additives, water treatment chemicals and cleaning agents, and the wastewater stream that each regulated toxic organic could potentially enter;
- d. Comparison of the toxics found in the effluent with the list of raw materials and selection of the most probable wastewater source;
- e. Evaluation of the toxics found in the effluent, but not on the raw materials list and determination of those formed as reaction products or by-products;
- f. Examination of sources such as equipment corrosion or raw materials' impurities that could result in release to wastewaters of toxic organic pollutants.

## Step 2 - Pollutant control evaluation

An evaluation should be made of the control options that could be implemented to eliminate the toxic compound(s) or the source or potential source of toxic organic compound introduction to the treatment system. This may include in-plant modifications, solvent or chemical substitution, partial or complete recycle, reuse, neutralization, and operational changes. The analysis should be conducted on a case-by-case basis and will often result in one or more feasible options to control each source or potential source of toxic pollutant discharge. Finally, evaluation of the available control options, including the advantages and disadvantages of each, may lead to a decision of whether a TOMP is a feasible alternative to TTO monitoring.

## Step 3 - Preparation of Toxic Organic Management Plan

A toxic organic management plan should include the following items at a minimum:

- a. A complete inventory of all toxic organic chemicals in use or identified through sampling and analysis of the wastewater from regulated process operations (organic constituents of trade-name products should be obtained from the appropriate suppliers as necessary);
- b. Descriptions of the methods of disposal other than dumping used for the inventoried compounds, such as reclamation, contract hauling, or incineration;
- c. The procedures for ensuring that the regulated toxic organic pollutants do not spill or routinely leak into process wastewaters, floor drains, non-contact cooling water, groundwater, surface waters (i.e., Spill Prevention, Control, and Countermeasures (SPCC) Plan) or any other location which allows discharge of the compounds; and
- d. Determinations or best estimates of the identities and approximate quantities of toxic organic pollutants used as well as discharged from the regulated manufacturing processes. Compounds present in wastestreams that are discharged to sanitary sewers may be a result of regulated processes or disposal, spills, leaks, rinse water carryover, air pollution control, and other sources.

Step 4 - Submission of Toxic Organic Management Plan and Certification Statement

The TOMP should be submitted to the Control Authority at the time the baseline monitoring report is required if the IU's initial election is to choose this option. Alternatively, an IU may submit a TOMP at any later time and request that TTO monitoring requirements be discontinued upon approval and implementation of the TOMP. A prerequisite for use of this certification approach is a fully approved, implemented, and ongoing toxic organic management plan. In addition, a certification statement must be included at the time of submission of the TOMP and with each subsequent IU report (i.e., semi-annual compliance report). It must be signed by an officer of the company or manager responsible for overall plant operations. A statement such as the following should be required.

"Based on my inquiry of the person or persons directly responsible for managing compliance with the TTO limitations, I certify that, to the best of my knowledge and belief, no dumping of concentrated toxic organics into the wastewaters has occurred since filing of the last report. I further certify that this facility is implementing the toxic organic pollutant management plan submitted to the Control Authority on (date to be specified).

(date)

(Officer)

If the user is unable to make the above certification statement, the user should notify the Control Authority sixty days (60) prior to the due date for filing the compliance reports. At that time, the Control Authority should determine the appropriateness of requiring sampling and analysis for specific toxicants and notify the user accordingly.

A sample Toxic Organic Management Plan and certification statement are included as Appendix D.

## APPENDIX D

Analytical Procedure for Determining  
Oil and Grease Concentrations Under  
Coil Coating Regulation

## APPENDIX D

### TOXIC ORGANIC MANAGEMENT PLAN ABC REFRIGERATION CORPORATION HIGH POINT PLANT

#### I. Description of Facilities and Solvent Use

##### A. Process Description

The ABC Refrigeration Corporation, High Point Plant, manufactures automotive radiators, condensers, and compressors from metal coils and metal castings manufactured by other suppliers. The forming and assembly processes include metal forming, degreasing, chromating, and brazing in preparation for painting and final assembly. The metal castings are machined, washed, assembled, and degreased prior to final assembly.

Wastewater types and volumes and the current wastewater treatment system are depicted in Figure 1. The primary sources of process wastewater are the degreasing, chromating, fluxing, and parts washing operations. Other sources of wastewater are cooling tower blowdown and boiler blowdown. Wastewater from the degreasing operations is treated by dispersed air floatation for oil and grease removal and then discharged to a combined wastestream containing the wastewater from all other sources. The combined wastestream is then treated by coagulation/flocculation with chemical and polymer addition for solids and metals reduction. The treated effluent is discharged to the city sewer system.

##### B. Identification of Toxic Organic Chemicals Entering the Plant Wastewaters

###### 1. Chemical Analysis of Treated Wastewaters

Samples were taken of the plant's treated wastewaters for analysis for the 110 toxic organics regulated under the metal finishing categorical pretreatment standards. Samples collected were 24-hour flow proportioned composite samples for acid extractible and base/neutral compounds. Grab samples for volatile organics were taken every four hours and were composited before analysis. Samples were taken over a period when all production lines were operating at peak production rates. Samples were analyzed by gas chromatography with compound identification and quantification by mass spectrophotometer (GC/MS). EPA procedures 624 and 625 were followed for GC/MS analysis. Toxic organic compounds detected at concentrations greater than 0.01 mg/l are listed in Table 1.




FIGURE 1  
 WASTEWATER GENERATION AND TREATMENT  
 ABC REFRIGERATION CORPORATION HIGH POINT PLANT

Table 1

Compound	Concentration (mg/l)
1,1,1-Trichloroethane	1.320
Napthalene	0.210
Chloroethane	0.131
Benzene	0.532
Phenol	0.681

2. Identification of Solvents Used in Manufacturing Operations

a. Greasefree is a degreasing solvent used in the forming process. Greasefree's principle ingredient is 1,1,1-trichloroethane. We have contacted the manufacturer of Greasefree, Doubt Chemical Corporation, who informs us that their analysis of Greasefree indicates that no other priority toxic pollutants are contained in Greasefree. Doubt's letter confirming its analysis is enclosed as Attachment 1.

b. Rinsewash is a degreasing solvent used in the metal castings process. Rinsewash is a multicomponent solvent we purchase from Pound Chemical Corporation. At our request Pound has analyzed Rinsewash and found it contains naphthalene, benzene, and phenol. Pound represents that no other toxic organic pollutants were identified in its analysis of Rinsewash. Pound's letter documenting its analysis is enclosed as Attachment 2.

c. Rustaway is a corrosion inhibitor used during the metal castings washing process to prevent rust formation. We buy Rustaway from the Exit Chemicals Corporation. The primary ingredient of Rustaway is carbon disulfide. Exit refused our request for a chemical analysis of Rustaway. We, therefore, submitted an aliquot of Rustaway to Whatsinit Laboratories, Inc. for analysis. Whatsinit's report is enclosed as Attachment 3 and documents that Rustaway contains chloroethane. No other toxic organics were detected.

3. Identification of Other Potential Sources of Toxic Organic Pollutant Introduction to the Wastewater Treatment System

a. Durable Paints are used to finish the forming process items. Although not detected in the wastewater analysis, Durable Paints are known to contain toluene. The floor drains in the forming process painting area discharge to the wastewater treatment system. Therefore, any spilled paint would enter the process wastewater treatment system.



b. Degreasing Areas - Floor drains in both degreasing areas similarly are connected to the main wastewater system. Therefore, spills of degreasing agents could enter the treatment system.

c. Solvent Storage Areas - Solvents, paints, and corrosion inhibitors are stored in bulk quantities in four different areas of the plant--the two degreasing areas, the washing area, and the painting area. Spills could occur by accidental dumping, spillage during routine transfer, etc. Such spills would enter the wastewater treatment system through the floor drains.

## II. Description of Control Options Explored

### A. Solvent Substitution

For the degreasing, corrosion inhibitor, and painting sources of toxic organics, ABC explored the feasibility of substituting another product that does not contain toxic organic materials. Obviously, this would be the most effective manner of eliminating toxic organic discharges both from process operations and from potential spillage into floor drains. ABC obtained samples of degreasing agents, corrosion inhibitors, and paints that do not contain toxic organics from vendors and conducted pilot tests of their effectiveness. ABC concluded after these tests that the alternative degreasing agents and paints could not be used without adversely affecting the process and final products. The alternative degreasing agents were not nearly as effective as the ones currently used and, therefore, would impair the effectiveness of subsequent operations. Alternative paints could not be applied evenly to our products. One alternative corrosion inhibitor, Chromisorb, appears to be an acceptable alternative to the Rustaway and contains the toxic metals zinc and chromium. Thus, the option of eliminating chloroethane discharges by substituting Chromasorb for Rustaway as a corrosion inhibitor was considered.

### B. Process Modifications

The major alternative to the substitution of degreasing agents is to institute changes in the degreasing process that do not result in wastewater discharge. This would be accomplished by wiping parts rather than rinsing them. After a thorough wipedown, parts would be air dried in an area under a vacuum hood. The vacuum hood is integrated with the facility's air pollution control devices. Any material used for wiping would, of course, be treated as a hazardous material. It would be transferred to drums and disposed of to a licensed disposer or reclaimer. Thus, process changes could be made that would eliminate discharge of process wastewaters containing 1,1,1-trichloroethane, naphthalene, benzene, and phenol. Solid waste generation would, of course, increase.

### C. Segregated Drain System

Spills of toxic organics could be eliminated from the process wastewater stream if a segregated floor drain system were constructed. ABC investigated this option and found that, because of the location of some existing drain pipes, such modification would require a major disruption of the plant and would cost far more than routine TTO monitoring. Moreover, such an option would create a significant additional wastewater treatment problem for those cases in which drained water is not contaminated by spilled material.

### D. Sealing Floor Drains

Introduction of toxic organics to wastewaters through floor drains could be eliminated if floor drains were sealed. In the process areas this option is not feasible because of State safety requirements. In storage areas, however, such an option may be practical.

### E. Installing Sumps in the Floor Drains

Under this option sumps would be installed such that prior to entering the drain, floor waters would pass through a sump or holding tank. The sump would be as large as the largest spill of solvent reasonably expected plus a 10 percent freeboard allowance. Thus, if a solvent spilled, the discharge to the drain would be turned off. The solvent could, then, collect in the sump and be recovered.

## III. Toxic Organic Management Plan

As a result of the above analyses, ABC believes that all of its toxic organic pollutant discharges can be controlled by a toxic organic management plan in lieu of routine toxic organic monitoring.

### A. Solvent Substitution

Discharge of chloroethane will be eliminated by use of a substitute rust inhibitor. ABC will discontinue use of Rustaway as a rust inhibitor. Instead, ABC will use Chromasorb to prevent rust formation in its metal casting line. Chromasorb is a zinc-chromate rust inhibitor that can be used to prevent rust formation in place of Rustaway. Chromasorb contains the toxic metals chromium and zinc. The existing wastewater treatment system, however, is designed to remove metallic pollutants. By adjustment of the chemical and polymer feed, ABC anticipates that it can maintain current levels of metals discharge while eliminating chloroethane discharges.



## F. Training

All personnel involved in degreasing, chromating, painting, and clean-up activities will receive instruction in the proper handling and disposal of solvents and clean-up materials in order to keep regulated toxic organics out of industrial wastewater. New employees will be trained in these procedures immediately. All personnel working in these activities are familiar with this toxic organic management plan and will follow the procedure established in that standard to eliminate regulated organics from entering the water wash system.

Training consists of classroom instruction which reviews the following:

1. The organic solvents and cleaners known to be in use at the plant and the areas in which they are used.
2. The location of lift stations and drains with emphasis upon the location of pretreatment sewer systems for each area in the plant.
3. The Toxic Organic Management Plan and the proper procedures for handling and disposing of the respective solvents.

## G. Inspections

1. Degreasers, spray booths, and cleaning operations will be inspected routinely by the area supervisor to verify cleaning procedures and adherence to this Toxic Organic Management Plan to insure that TTO does not spill or leak into plant sewers.
2. Centrally located cleaning and solvent handling, reuse, and collection areas, as well as raw material and waste solvent storage areas, will be inspected weekly by a designated environmental representative to verify proper solvent storage, handling, and collection. A log of inspections and sign-off will be maintained by the designated environmental representative.

## H. Implementation

All provisions of this plan will be fully implemented by April 1, 1984.

#### IV. Certification

"Based on my inquiry of the person or persons directly responsible for managing compliance with the TTO limitations, I certify that, to the best of my knowledge and belief, no dumping of concentrated toxic organics into the wastewaters has occurred since filing of the last report. I further certify that this facility is implementing this toxic organic pollutant management plan submitted to the Control Authority on January 2, 1984."

John Smith  
Plant Manager  
High Point Plant  
Telephone: (617) 617-6176