

ARTICLE 4. PRETREATMENT STANDARDS.

§ 15-10-41 NATIONAL PRETREATMENT STANDARDS.

Except as otherwise provided in this chapter, a person must comply with the categorical pretreatment standards established by 40 CFR Chapter I, Subchapter N, Parts 405-471.

Source: 1992 Code Section 18-2-41.

§ 15-10-42 EXCEPTIONS TO CATEGORICAL PRETREATMENT STANDARDS.

- (A) The director may impose equivalent concentration or mass limits in accordance with 40 CFR 403.6(c) if a pretreatment standard is expressed only in terms of either pollutant mass or concentration in wastewater.
- (B) The director shall impose an alternate limit using the combined waste stream formula in 40 CFR 403.6(e) if wastewater subject to a pretreatment standard is mixed with wastewater not regulated by the same standard.
- (C) The director may grant a variance to a person subject to a categorical pretreatment standard if the person proves under 40 CFR 403.13 that factors relating to the person's discharge are fundamentally different from the factors considered by EPA in developing the categorical pretreatment standard.
- (D) The director may grant an adjustment to a person subject to a categorical pretreatment standard under 40 CFR 403.15.

Source: 1992 Code Section 18-2-42.

§ 15-10-43 STATE PRETREATMENT STANDARDS.

Except as otherwise provided in this chapter, a person must comply with the pretreatment standards established by the State of Texas.

Source: 1992 Code Section 18-2-43.

§ 15-10-44 LOCAL LIMITS.

A person shall not discharge or allow the discharge to the POTW of wastewater containing the following individually identified specific pollutants in concentrations, solution, or suspension that exceed the following limits:

Pollutant	Milligrams per Liter
(1) Arsenic, Total (T)	0.2
(2) Cadmium (T)	0.4
(3) Chromium (T)	2.4
(4) Copper (T)	1.1
(5) Cyanide (T)	1.0
(6) Fluoride (T)	65.0
(7) Lead (T)	0.4
(8) Manganese (T)	6.1
(9) Mercury (T)	0.002
(10) Molybdenum (T)	1.1
(11) Nickel (T)	1.6
(12) Selenium (T)	1.8
(13) Silver (T)	1.0
(14) Zinc (T)	2.3

Source: 1992 Code Section 18-2-44.

§ 15-10-45 TOTAL TOXIC ORGANICS.

A person may not discharge or allow the discharge of wastewater containing total toxic organics to the POTW in excess of an instantaneous maximum allowable limit of 2.0 milligrams per liter.

Source: 1992 Code Section 18-2-45.

§ 15-10-46 COMPLIANCE DETERMINATION; ASSIGNMENT OF LIMITS.

- (A) The director may determine compliance with the local limits or the total toxic organics limit based on the analysis of:
- (1) A grab sample; or
 - (2) A combination of grab samples, time composite samples, or flow composite samples.
- (B) If necessary to protect the POTW or sanitary sewer, the director may issue a permit, order, or rule that assigns the local limits or the total toxic organics limit as:
- (1) instantaneous maximum allowable limits;
 - (2) daily average limits;
 - (3) daily maximum limits;
 - (4) monthly average limits; or
 - (5) limits of other sampling duration or averaging period.

Source: 1992 Code Section 18-2-46.