



**CITY OF AUSTIN
STANDARD PRODUCTS LIST**

for

AIR RELEASE/VACUUM RELIEF VALVES FOR POTABLE WATER

USING DEPARTMENT: Austin Water

PREPARED BY: Robert Lamb, P.E.

ISSUED: 10/01/03

REVISED BY: Jeff Kyle, P.E.

REVISED: 07/01/18

DESCRIPTION: Air release (combination, automatic)/vacuum relief valve for potable water service only, size and optional features to be shown on approved engineering drawings. Must comply with AWWA C512. Effective January 1, 2013, valves purchased for City forces shall be "lead free" and marked by stamping, etching, or casting "NL" in the main body or by other methods acceptable to City. Effective January 4, 2014, all valves must be "lead free."

LISTING DATE	MANUFACTURER	PRODUCT IDENTIFICATION/COMMENT	APPROVAL
10/01/03	A.R.I. FLOW CONTROL C/O McCain Waterworks Marketing Suite 1202 18975 Marbach Lane San Antonio, TX 78266	D-040 D-060	R. Lamb
04/01/04	BERMAD 9424 West Little York Rd Houston, TX 77040	Model C75	R. Lamb
07/01/10	DEZURIK/APCO (formerly APCO VALVE & PRIMER CORP.) 250 Riverside Ave N Sartell, MN 56377	Series 1800	R. Lamb
07/01/18	H-TEC 1061 Triad Court, West Oak Business Park II, Ste. 5 Marietta, GA 30062	Models 992 & 993	J. Kyle

NOTES:

LATEST REVISIONS:

1. Change BERMAD Address and Model number
2. Change APCO/VALVE AND PRIMER CORP to DEZURIK/APCO
3. Add H-TEC to the SPL