



**CITY OF AUSTIN  
 STANDARD PRODUCTS LIST  
 for  
 TRACER TAPE**

**USING DEPARTMENT:** Water Utility      **ISSUED:** 01/26/99      **REVIEWED:** 07/01/13      **REVISED:** 07/01/13

**PREPARED BY:** David Rinn      **CITY STOCK NUMBER:**

**DESCRIPTION:** Tape, locating, inductive, detectable, 5 mil minimum overall thickness and 0.34 mil minimum thickness solid aluminum foil core. All brands shall be a minimum of 12" wide and placed no deeper than 36". The tape shall be color-coded according to the American Public Works Association Uniform Color Code: blue for potable water, purple for reclaimed water, and green for wastewater

| <b>LISTING DATE</b> | <b>MANUFACTURER</b>  | <b>PRODUCT IDENTIFICATION/COMMENT</b> | <b>APPROVAL</b> |
|---------------------|--|---------------------------------------|-----------------|
| 01/26/99            | PRO-LINE SAFETY PRODUCTS CO.<br>1099 Atlantic Drive<br>Unit #1<br>West Chicago, IL 60185               |                                       | D. Rinn         |
| 01/26/99            | UNITED SAFETY AUTHORITY OF OHIO<br>P.O. Box 336<br>Southington, OH 44470-0366                          |                                       | D. Rinn         |
| 07/01/13            | DALIAN METALS I/E, CO. LTD. (China)<br>ACCUCAST<br>415 South 21 <sup>ST</sup> Street<br>Waco, TX 76706 |                                       | R. Lamb         |

**NOTE:**