

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 06/01/2024 - 06/30/2024

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.8	Avg	9.8	Avg	9.6	
		Max	9.9	Max	9.8	Max	9.8	
		Min	9.6	Min	9.6	Min	9.6	
Total Alkalinity	mg/L as CaCO3	Avg	61	Avg	59	Avg	76	
		Max	66	Max	64	Max	80	
		Min	56	Min	54	Min	73	
Total Hardness	mg/L as CaCO3	Avg	97	Avg	96	Avg	107	
		Max	102	Max	100	Max	110	
		Min	92	Min	92	Min	102	
Total Solids	mg/L	Avg	230	Avg	244	Avg	262	
		Max	250	Max	254	Max	274	
		Min	216	Min	232	Min	254	
Total Chloramines	mg/L	Avg	2.74	Avg	2.54	Avg	2.64	
		Max	2.95	Max	2.70	Max	2.75	
		Min	2.55	Min	2.40	Min	2.50	
Total Organic Carbon	mg/L	Avg	2.83	Avg	2.77	Avg	2.74	
		Max	2.93	Max	2.87	Max	2.83	
		Min	2.66	Min	2.67	Min	2.69	
Conductivity	umhos/cm	Avg	376	Avg	372	Avg	418	
		Max	379	Max	372	Max	418	
		Min	372	Min	372	Min	418	
Total Trihalomethanes	ug/L	Avg	52.7	Avg	49.8	Avg	33.8	
		Max	53.6	Max	49.8	Max	33.8	
		Min	51.8	Min	49.8	Min	33.8	
Turbidity	NTU	Avg	.03	Avg	.03	Avg	.02	
		Max	.04	Max	.06	Max	.04	
		Min	.03	Min	.02	Min	.02	