

Drinking Water Quality Report
Date Range: 01-NOV-2019 to 30-NOV-2019

| Parameter | Units | Method Cd | Davis WTP | | Ullrich WTP | | WTP 4 | |
|-----------------------|----------|---------------|-----------|--------|-------------|------|-------|------|
| | | | | T2,T2H | | T3 | | T4 |
| pH | SU | SM 4500-H B | AVG | 9.6 | AVG | 9.6 | AVG | 9.6 |
| | | | MAX | 9.7 | MAX | 9.8 | MAX | 9.7 |
| | | | MIN | 9.5 | MIN | 9.4 | MIN | 9.5 |
| Total Alkalinity | MG/L | SM 2320 B | AVG | 60 | AVG | 59 | AVG | 68 |
| | | | MAX | 67 | MAX | 64 | MAX | 76 |
| | | | MIN | 56 | MIN | 48 | MIN | 63 |
| Total Hardness | MG/L | SM 2340 C | AVG | 87 | AVG | 87 | AVG | 90 |
| | | | MAX | 92 | MAX | 97 | MAX | 96 |
| | | | MIN | 83 | MIN | 81 | MIN | 84 |
| Total Solids | MG/L | SM 2540 B | AVG | 122 | AVG | 129 | AVG | 149 |
| | | | MAX | 154 | MAX | 184 | MAX | 178 |
| | | | MIN | 100 | MIN | 78 | MIN | 134 |
| Chloramines | MG/L | SM 4500-CL F | AVG | 2.89 | AVG | 2.83 | AVG | 2.83 |
| | | | MAX | 3.10 | MAX | 3.05 | MAX | 3.00 |
| | | | MIN | 2.80 | MIN | 2.70 | MIN | 2.65 |
| Sulfate | MG/L | SM 4500-SO4 E | AVG | 37.6 | AVG | 41.2 | AVG | 43.3 |
| | | | MAX | 37.6 | MAX | 41.2 | MAX | 43.3 |
| | | | MIN | 37.6 | MIN | 41.2 | MIN | 43.3 |
| Total Organic Carbon | MG/L | SM 5310 C | AVG | 2.67 | AVG | 2.51 | AVG | 2.49 |
| | | | MAX | 2.91 | MAX | 2.70 | MAX | 2.62 |
| | | | MIN | 2.47 | MIN | 2.41 | MIN | 2.39 |
| Conductivity | UMHOS/cm | SM 2510 B | AVG | 270 | AVG | 274 | AVG | 314 |
| | | | MAX | 270 | MAX | 274 | MAX | 314 |
| | | | MIN | 270 | MIN | 274 | MIN | 314 |
| Total Trihalomethanes | UG/L | EPA 524.3 THM | AVG | 31.6 | AVG | 38.1 | AVG | 32.4 |
| | | | MAX | 34.5 | MAX | 39.5 | MAX | 33.4 |
| | | | MIN | 26.7 | MIN | 36.8 | MIN | 31.2 |
| Turbidity | NTU | SM 2130 B | AVG | 0.05 | AVG | 0.04 | AVG | 0.03 |
| | | | MAX | 0.07 | MAX | 0.06 | MAX | 0.05 |
| | | | MIN | 0.02 | MIN | 0.03 | MIN | 0.02 |