

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 10/01/2021 - 10/31/2021

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6
		Max	9.7	Max	9.8	Max	9.7
		Min	9.6	Min	9.6	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	54	Avg	56	Avg	64
		Max	59	Max	62	Max	66
		Min	49	Min	50	Min	62
Total Hardness	mg/L as CaCO3	Avg	83	Avg	88	Avg	89
		Max	86	Max	92	Max	92
		Min	80	Min	84	Min	86
Total Solids	mg/L	Avg	165	Avg	173	Avg	186
		Max	196	Max	194	Max	204
		Min	132	Min	150	Min	162
Total Chloramines	mg/L	Avg	2.80	Avg	2.64	Avg	2.50
		Max	3.00	Max	2.75	Max	2.80
		Min	2.70	Min	2.50	Min	2.40
Total Organic Carbon	mg/L	Avg	2.50	Avg	2.39	Avg	2.23
		Max	2.74	Max	2.54	Max	2.26
		Min	2.30	Min	2.22	Min	2.17
Conductivity	umhos/cm	Avg	297	Avg	305	Avg	343
		Max	299	Max	307	Max	346
		Min	293	Min	303	Min	339
Turbidity	NTU	Avg	0.06	Avg	0.03	Avg	0.04
		Max	0.10	Max	0.16	Max	0.07
		Min	0.05	Min	0.01	Min	0.02