

Drinking Water Quality Report  
Date Range: 01-JAN-2010 to 31-JAN-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.4
			MAX	9.7	MAX	9.6
			MIN	9.5	MIN	9.3
Total Alkalinity	MG/L	SM 2320 B	AVG	66	AVG	63
			MAX	70	MAX	69
			MIN	56	MIN	58
Total Hardness	MG/L	SM 2340 C	AVG	109	AVG	108
			MAX	113	MAX	112
			MIN	99	MIN	104
Total Solids	MG/L	SM 2540 B	AVG	206	AVG	212
			MAX	224	MAX	226
			MIN	194	MIN	197
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.57	AVG	2.51
			MAX	2.75	MAX	2.65
			MIN	2.12	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	45.5	AVG	46.5
			MAX	51.0	MAX	48.2
			MIN	40.3	MIN	44.8
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.81	AVG	2.61
			MAX	2.93	MAX	2.76
			MIN	2.67	MIN	2.48
Conductivity	UMHOS/cm	SM 2510 B	AVG	350	AVG	347
			MAX	356	MAX	349
			MIN	342	MIN	345
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	18.2	AVG	31.4
			MAX	27.3	MAX	31.2
			MIN	14.5	MIN	31.6
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04
			MAX	0.10	MAX	0.05
			MIN	0.05	MIN	0.03