

Drinking Water Quality Report
Date Range: 01-MAR-2010 to 31-MAR-2010

| Parameter ----- | Units ---- | Method Cd ----- | Davis WTP | | Ullrich WTP | |
|-------------------------|---------------|--------------------|-----------|-----------------|-------------|-------------|
| | | | | T2,T2H ----- | | T3 ----- |
| pH | SU | SM 4500-H B | AVG | 9.7 | AVG | 9.5 |
| | | | MAX | 9.9 | MAX | 9.6 |
| | | | MIN | 9.6 | MIN | 9.4 |
| Total Alkalinity | MG/L | SM 2320 B | AVG | 61 | AVG | 60 |
| | | | MAX | 69 | MAX | 70 |
| | | | MIN | 53 | MIN | 54 |
| Total Hardness | MG/L | SM 2340 C | AVG | 108 | AVG | 109 |
| | | | MAX | 116 | MAX | 118 |
| | | | MIN | 101 | MIN | 98 |
| Total Solids | MG/L | SM 2540 B | AVG | 224 | AVG | 221 |
| | | | MAX | 234 | MAX | 228 |
| | | | MIN | 206 | MIN | 203 |
| Total Chlorine Residual | MG/L | SM 4500-CL F | AVG | 2.51 | AVG | 2.47 |
| | | | MAX | 2.75 | MAX | 2.65 |
| | | | MIN | 2.30 | MIN | 2.35 |
| Sulfate | MG/L | SM 4500-SO4 E | AVG | 49.8 | AVG | 50.8 |
| | | | MAX | 51.7 | MAX | 52.4 |
| | | | MIN | 48.9 | MIN | 49.1 |
| Total Organic Carbon | MG/L | SM 5310 C | AVG | 2.52 | AVG | 2.27 |
| | | | MAX | 2.72 | MAX | 2.52 |
| | | | MIN | 2.34 | MIN | 2.07 |
| Conductivity | UMHOS/cm | SM 2510 B | AVG | 349 | AVG | 355 |
| | | | MAX | 355 | MAX | 355 |
| | | | MIN | 345 | MIN | 355 |
| Total Trihalomethanes | UG/L | EPA 524.2 THM | AVG | 14.2 | AVG | 22.3 |
| | | | MAX | 25.8 | MAX | 26.9 |
| | | | MIN | 9.7 | MIN | 11.0 |
| Turbidity | NTU | SM 2130 B | AVG | 0.07 | AVG | 0.03 |
| | | | MAX | 0.10 | MAX | 0.05 |
| | | | MIN | 0.06 | MIN | 0.02 |