

Drinking Water Quality Report
Date Range: 01-MAY-2010 to 31-MAY-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.8	AVG	9.5
			MAX	10.0	MAX	9.7
			MIN	9.6	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	67	AVG	64
			MAX	69	MAX	68
			MIN	64	MIN	60
Total Hardness	MG/L	SM 2340 C	AVG	96	AVG	93
			MAX	100	MAX	97
			MIN	92	MIN	92
Total Solids	MG/L	SM 2540 B	AVG	181	AVG	178
			MAX	184	MAX	184
			MIN	176	MIN	172
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.68	AVG	2.45
			MAX	2.75	MAX	2.55
			MIN	2.58	MIN	2.30
Sulfate	MG/L	SM 4500-SO4 E	AVG	35.6	AVG	34.6
			MAX	38.0	MAX	35.5
			MIN	31.6	MIN	33.7
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.65	AVG	2.50
			MAX	2.76	MAX	2.62
			MIN	2.54	MIN	2.37
Conductivity	UMHOS/cm	SM 2510 B	AVG	303	AVG	299
			MAX	307	MAX	302
			MIN	299	MIN	295
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	33.4	AVG	34.6
			MAX	37.0	MAX	37.0
			MIN	29.1	MIN	32.5
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.02
			MAX	0.10	MAX	0.04
			MIN	0.04	MIN	0.02