

Drinking Water Quality Report
Date Range: 01-NOV-2010 to 30-NOV-2010

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	10.0	MAX	9.8
			MIN	9.6	MIN	9.3
Total Alkalinity	MG/L	SM 2320 B	AVG	66	AVG	66
			MAX	74	MAX	72
			MIN	59	MIN	56
Total Hardness	MG/L	SM 2340 C	AVG	94	AVG	94
			MAX	100	MAX	100
			MIN	88	MIN	87
Total Solids	MG/L	SM 2540 B	AVG	158	AVG	157
			MAX	176	MAX	170
			MIN	144	MIN	142
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.61	AVG	2.49
			MAX	2.75	MAX	2.70
			MIN	2.35	MIN	2.30
Sulfate	MG/L	SM 4500-SO4 E	AVG	36.3	AVG	37.7
			MAX	38.1	MAX	38.3
			MIN	32.3	MIN	37.1
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.69	AVG	2.66
			MAX	2.87	MAX	2.78
			MIN	2.48	MIN	2.48
Conductivity	UMHOS/cm	SM 2510 B	AVG	287	AVG	283
			MAX	292	MAX	284
			MIN	281	MIN	281
Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	45.5	AVG	35.2
			MAX	107.0	MAX	59.7
			MIN	24.0	MIN	23.2
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.05
			MAX	0.10	MAX	0.11
			MIN	0.02	MIN	0.03