

Drinking Water Quality Report
Date Range: 01-OCT-2011 to 31-OCT-2011

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.7
			MAX	9.8	MAX	9.9
			MIN	9.6	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	71	AVG	72
			MAX	76	MAX	78
			MIN	64	MIN	64
Total Hardness	MG/L	SM 2340 C	AVG	97	AVG	99
			MAX	102	MAX	106
			MIN	90	MIN	90
Total Solids	MG/L	SM 2540 B	AVG	179	AVG	181
			MAX	191	MAX	202
			MIN	150	MIN	148
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.65	AVG	2.36
			MAX	2.80	MAX	2.55
			MIN	2.50	MIN	1.45
Sulfate	MG/L	SM 4500-SO4 E	AVG	31.8	AVG	26.6
			MAX	32.4	MAX	26.6
			MIN	31.1	MIN	26.6
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.59	AVG	2.58
			MAX	2.70	MAX	2.74
			MIN	2.48	MIN	2.39
Conductivity	UMHOS/cm	SM 2510 B	AVG	319	AVG	321
			MAX	320	MAX	321
			MIN	318	MIN	321
Total Trihalomethanes	UG/L	EPA 524.2 THM & EPA 524.3 THM	AVG	38.8	AVG	30.2
			MAX	48.1	MAX	36.2
			MIN	30.8	MIN	25.8
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.05
			MAX	0.10	MAX	0.10
			MIN	0.03	MIN	0.03