

Drinking Water Quality Report
Date Range: 01-DEC-2012 to 31-DEC-2012

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.5
			MAX	9.9	MAX	9.6
			MIN	9.6	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	80	AVG	78
			MAX	84	MAX	88
			MIN	77	MIN	69
Total Hardness	MG/L	SM 2340 C	AVG	113	AVG	112
			MAX	119	MAX	123
			MIN	110	MIN	103
Total Solids	MG/L	SM 2540 B	AVG	205	AVG	204
			MAX	220	MAX	220
			MIN	182	MIN	177
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.66	AVG	2.54
			MAX	2.90	MAX	2.85
			MIN	2.50	MIN	2.40
Sulfate	MG/L	SM 4500-SO4 E	AVG	44.7	AVG	39.1
			MAX	45.1	MAX	39.1
			MIN	44.2	MIN	39.1
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.79	AVG	2.74
			MAX	2.91	MAX	2.90
			MIN	2.69	MIN	2.63
Conductivity	UMHOS/cm	SM 2510 B	AVG	372	AVG	370
			MAX	373	MAX	370
			MIN	371	MIN	370
Total Trihalomethanes	UG/L	EPA 524.2 THM & EPA 524.3 THM	AVG	19.1	AVG	30.5
			MAX	34.8	MAX	35.4
			MIN	8.3	MIN	26.1
Turbidity	NTU	SM 2130 B	AVG	0.09	AVG	0.04
			MAX	0.21	MAX	0.07
			MIN	0.06	MIN	0.03