

Drinking Water Quality Report
Date Range: 01-JAN-2012 to 31-JAN-2012

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.5	AVG	9.6
			MAX	9.6	MAX	9.7
			MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	80	AVG	75
			MAX	85	MAX	82
			MIN	69	MIN	57
Total Hardness	MG/L	SM 2340 C	AVG	116	AVG	112
			MAX	122	MAX	118
			MIN	107	MIN	96
Total Solids	MG/L	SM 2540 B	AVG	210	AVG	209
			MAX	234	MAX	236
			MIN	186	MIN	178
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.61	AVG	2.65
			MAX	2.75	MAX	2.95
			MIN	2.50	MIN	2.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	45.4	AVG	39.8
			MAX	46.3	MAX	39.8
			MIN	44.5	MIN	39.8
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.70	AVG	2.54
			MAX	2.78	MAX	2.65
			MIN	2.60	MIN	2.43
Conductivity	UMHOS/cm	SM 2510 B	AVG	375	AVG	372
			MAX	377	MAX	372
			MIN	372	MIN	372
*Total Trihalomethanes	UG/L	EPA 524.2 THM	AVG	39.9	AVG	35.8
			MAX	44.7	MAX	38.9
			MIN	34.2	MIN	32.8
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04
			MAX	0.10	MAX	0.06
			MIN	0.06	MIN	0.02