

Drinking Water Quality Report
Date Range: 01-JUL-2012 to 31-JUL-2012

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.7
			MAX	9.9	MAX	9.8
			MIN	9.5	MIN	9.6
Total Alkalinity	MG/L	SM 2320 B	AVG	62	AVG	67
			MAX	73	MAX	86
			MIN	54	MIN	54
Total Hardness	MG/L	SM 2340 C	AVG	94	AVG	101
			MAX	106	MAX	118
			MIN	86	MIN	89
Total Solids	MG/L	SM 2540 B	AVG	184	AVG	189
			MAX	206	MAX	215
			MIN	157	MIN	154
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.62	AVG	2.47
			MAX	3.00	MAX	2.75
			MIN	2.02	MIN	2.05
Sulfate	MG/L	SM 4500-SO4 E	AVG	35.5	AVG	34.4
			MAX	36.0	MAX	34.4
			MIN	35.0	MIN	34.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.70	AVG	2.65
			MAX	2.87	MAX	2.76
			MIN	2.54	MIN	2.58
Conductivity	UMHOS/cm	SM 2510 B	AVG	360	AVG	364
			MAX	361	MAX	364
			MIN	359	MIN	364
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	45.9	AVG	41.6
			MAX	67.7	MAX	47.7
			MIN	19.2	MIN	35.1
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.05
			MAX	0.17	MAX	0.09
			MIN	0.04	MIN	0.02