

Drinking Water Quality Report
Date Range: 01-JUN-2012 to 30-JUN-2012

Parameter -----	Units -----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.7
			MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	64	AVG	70
			MAX	71	MAX	87
			MIN	56	MIN	65
Total Hardness	MG/L	SM 2340 C	AVG	97	AVG	103
			MAX	103	MAX	120
			MIN	90	MIN	99
Total Solids	MG/L	SM 2540 B	AVG	201	AVG	206
			MAX	218	MAX	224
			MIN	174	MIN	180
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.53	AVG	2.26
			MAX	2.82	MAX	2.60
			MIN	2.05	MIN	1.50
Sulfate	MG/L	SM 4500-SO4 E	AVG	34.7	AVG	34.3
			MAX	36.0	MAX	34.3
			MIN	33.4	MIN	34.3
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.83	AVG	2.76
			MAX	3.02	MAX	2.86
			MIN	2.67	MIN	2.57
Conductivity	UMHOS/cm	SM 2510 B	AVG	341	AVG	353
			MAX	342	MAX	353
			MIN	339	MIN	353
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	45.1	AVG	34.3
			MAX	51.7	MAX	37.3
			MIN	38.4	MIN	27.5
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.06
			MAX	0.10	MAX	0.09
			MIN	0.04	MIN	0.03