

Drinking Water Quality Report  
Date Range: 01-NOV-2012 to 30-NOV-2012

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.6	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	78	AVG	73
			MAX	85	MAX	82
			MIN	72	MIN	66
Total Hardness	MG/L	SM 2340 C	AVG	110	AVG	109
			MAX	117	MAX	120
			MIN	103	MIN	100
Total Solids	MG/L	SM 2540 B	AVG	184	AVG	182
			MAX	214	MAX	212
			MIN	160	MIN	166
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.68	AVG	2.58
			MAX	2.78	MAX	2.75
			MIN	2.60	MIN	2.45
Sulfate	MG/L	SM 4500-SO4 E	AVG	35.6	AVG	37.6
			MAX	36.4	MAX	37.6
			MIN	34.8	MIN	37.6
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.74	AVG	2.61
			MAX	2.89	MAX	2.73
			MIN	2.57	MIN	2.48
Conductivity	UMHOS/cm	SM 2510 B	AVG	368	AVG	364
			MAX	368	MAX	364
			MIN	367	MIN	364
Total Trihalomethanes	UG/L	EPA 524.2 THM & EPA 524.3 THM	AVG	19.1	AVG	32.9
			MAX	21.6	MAX	35.8
			MIN	12.3	MIN	27.4
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04
			MAX	0.15	MAX	0.08
			MIN	0.05	MIN	0.03