

Drinking Water Quality Report
Date Range: 01-OCT-2012 to 31-OCT-2012

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.8	AVG	9.6
			MAX	9.9	MAX	9.8
			MIN	9.6	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	74	AVG	69
			MAX	79	MAX	82
			MIN	70	MIN	61
Total Hardness	MG/L	SM 2340 C	AVG	106	AVG	105
			MAX	111	MAX	117
			MIN	101	MIN	98
Total Solids	MG/L	SM 2540 B	AVG	210	AVG	204
			MAX	218	MAX	214
			MIN	200	MIN	198
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.60	AVG	2.49
			MAX	2.75	MAX	2.70
			MIN	2.40	MIN	2.35
Sulfate	MG/L	SM 4500-SO4 E	AVG	40.0	AVG	40.0
			MAX	40.2	MAX	40.0
			MIN	39.8	MIN	40.0
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.71	AVG	2.46
			MAX	2.82	MAX	2.63
			MIN	2.61	MIN	2.33
Conductivity	UMHOS/cm	SM 2510 B	AVG	361	AVG	359
			MAX	364	MAX	359
			MIN	358	MIN	359
Total Trihalomethanes	UG/L	EPA 524.2 THM & EPA 524.3 THM	AVG	31.4	AVG	32.5
			MAX	40.9	MAX	35.2
			MIN	15.9	MIN	29.4
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.04
			MAX	0.15	MAX	0.09
			MIN	0.04	MIN	0.02