

Drinking Water Quality Report
Date Range: 01-AUG-2013 to 31-AUG-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.6	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	64	AVG	65
			MAX	71	MAX	70
			MIN	59	MIN	61
Total Hardness	MG/L	SM 2340 C	AVG	97	AVG	99
			MAX	103	MAX	104
			MIN	92	MIN	96
Total Solids	MG/L	SM 2540 B	AVG	192	AVG	192
			MAX	209	MAX	202
			MIN	176	MIN	180
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.81	AVG	2.49
			MAX	3.10	MAX	2.75
			MIN	2.70	MIN	2.30
Sulfate	MG/L	SM 4500-SO4 E	AVG	35.7	AVG	32.8
			MAX	37.2	MAX	32.8
			MIN	34.1	MIN	32.8
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.78	AVG	2.59
			MAX	3.03	MAX	2.70
			MIN	2.59	MIN	2.45
Conductivity	UMHOS/cm	SM 2510 B	AVG	338	AVG	342
			MAX	339	MAX	342
			MIN	337	MIN	342
Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	30.5	AVG	33.5
			MAX	40.2	MAX	36.2
			MIN	22.0	MIN	30.7
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03
			MAX	0.08	MAX	0.07
			MIN	0.04	MIN	0.02