

Drinking Water Quality Report
Date Range: 01-FEB-2013 to 29-FEB-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.9	MAX	9.7
			MIN	9.5	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	74	AVG	76
			MAX	82	MAX	80
			MIN	70	MIN	68
Total Hardness	MG/L	SM 2340 C	AVG	110	AVG	114
			MAX	118	MAX	118
			MIN	106	MIN	110
Total Solids	MG/L	SM 2540 B	AVG	186	AVG	198
			MAX	215	MAX	228
			MIN	166	MIN	172
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.63	AVG	2.54
			MAX	2.75	MAX	2.70
			MIN	2.50	MIN	2.35
Sulfate	MG/L	SM 4500-SO4 E	AVG	41.0	AVG	42.4
			MAX	43.0	MAX	42.4
			MIN	38.9	MIN	42.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.67	AVG	2.71
			MAX	2.85	MAX	2.79
			MIN	2.51	MIN	2.64
Conductivity	UMHOS/cm	SM 2510 B	AVG	366	AVG	371
			MAX	370	MAX	371
			MIN	361	MIN	371
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	32.9	AVG	34.4
			MAX	34.1	MAX	35.5
			MIN	31.4	MIN	33.7
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03
			MAX	0.09	MAX	0.06
			MIN	0.04	MIN	0.02