

Drinking Water Quality Report
Date Range: 01-SEP-2013 to 30-SEP-2013

Parameter -----	Units ----	Method Cd -----	Davis WTP		Ullrich WTP	
				T2,T2H -----		T3 -----
pH	SU	SM 4500-H B	AVG	9.7	AVG	9.6
			MAX	9.8	MAX	9.8
			MIN	9.5	MIN	9.4
Total Alkalinity	MG/L	SM 2320 B	AVG	61	AVG	67
			MAX	65	MAX	72
			MIN	56	MIN	62
Total Hardness	MG/L	SM 2340 C	AVG	94	AVG	102
			MAX	99	MAX	106
			MIN	89	MIN	96
Total Solids	MG/L	SM 2540 B	AVG	188	AVG	198
			MAX	204	MAX	202
			MIN	168	MIN	188
Total Chlorine Residual	MG/L	SM 4500-CL F	AVG	2.93	AVG	2.61
			MAX	3.25	MAX	2.80
			MIN	2.70	MIN	2.30
Sulfate	MG/L	SM 4500-SO4 E	AVG	36.4	AVG	34.4
			MAX	37.5	MAX	34.4
			MIN	35.3	MIN	34.4
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.70	AVG	2.60
			MAX	2.96	MAX	2.73
			MIN	2.45	MIN	2.46
Conductivity	UMHOS/cm	SM 2510 B	AVG	335	AVG	354
			MAX	335	MAX	354
			MIN	335	MIN	354
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	28.9	AVG	35.9
			MAX	32.4	MAX	42.9
			MIN	24.8	MIN	30.8
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.04
			MAX	0.10	MAX	0.06
			MIN	0.03	MIN	0.02