

Drinking Water Quality Report
Date Range: 01-JAN-2017 to 31-JAN-2017

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.7	MAX	9.7
			MIN	9.5	MIN	9.4	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	59	AVG	59	AVG	66
			MAX	66	MAX	66	MAX	72
			MIN	53	MIN	53	MIN	60
Total Hardness	MG/L	SM 2340 C	AVG	86	AVG	87	AVG	87
			MAX	92	MAX	93	MAX	92
			MIN	79	MIN	80	MIN	82
Total Solids	MG/L	SM 2540 B	AVG	160	AVG	152	AVG	163
			MAX	174	MAX	156	MAX	182
			MIN	152	MIN	146	MIN	151
Chloramines	MG/L	SM 4500-CL F	AVG	2.97	AVG	2.92	AVG	2.85
			MAX	3.10	MAX	3.15	MAX	3.00
			MIN	2.85	MIN	2.25	MIN	2.70
Sulfate	MG/L	SM 4500-SO4 E	AVG	27.0	AVG	38.0	AVG	27.0
			MAX	27.1	MAX	37.8	MAX	27.3
			MIN	27.1	MIN	37.8	MIN	27.3
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.87	AVG	2.79	AVG	2.83
			MAX	3.17	MAX	3.11	MAX	2.93
			MIN	2.68	MIN	2.60	MIN	2.70
Conductivity	UMHOS/cm	SM 2510 B	AVG	297	AVG	290	AVG	304
			MAX	297	MAX	290	MAX	304
			MIN	297	MIN	290	MIN	304
Total Trihalomethanes	UG/L	EPA 524.3 THM	AVG	31.3	AVG	41.4	AVG	36.7
			MAX	42.4	MAX	47.4	MAX	41.2
			MIN	17.1	MIN	36.4	MIN	32.7
Turbidity	NTU	SM 2130 B	AVG	0.07	AVG	0.03	AVG	0.04
			MAX	0.10	MAX	0.08	MAX	0.06
			MIN	0.04	MIN	0.02	MIN	0.02