

Drinking Water Quality Report  
Date Range: 01-JUL-2017 to 31-JUL-2017

| Parameter             | Units    | Method Cd     | Davis WTP |        | Ullrich WTP |      | WTP 4 |      |
|-----------------------|----------|---------------|-----------|--------|-------------|------|-------|------|
|                       |          |               |           | T2,T2H |             | T3   |       | T4   |
| pH                    | SU       | SM 4500-H B   | AVG       | 9.7    | AVG         | 9.7  | AVG   | 9.7  |
|                       |          |               | MAX       | 9.8    | MAX         | 9.9  | MAX   | 9.8  |
|                       |          |               | MIN       | 9.5    | MIN         | 9.5  | MIN   | 9.6  |
| Total Alkalinity      | MG/L     | SM 2320 B     | AVG       | 60     | AVG         | 58   | AVG   | 62   |
|                       |          |               | MAX       | 64     | MAX         | 65   | MAX   | 65   |
|                       |          |               | MIN       | 52     | MIN         | 50   | MIN   | 59   |
| Total Hardness        | MG/L     | SM 2340 C     | AVG       | 83     | AVG         | 82   | AVG   | 80   |
|                       |          |               | MAX       | 87     | MAX         | 88   | MAX   | 84   |
|                       |          |               | MIN       | 74     | MIN         | 75   | MIN   | 77   |
| Total Solids          | MG/L     | SM 2540 B     | AVG       | 136    | AVG         | 141  | AVG   | 152  |
|                       |          |               | MAX       | 146    | MAX         | 152  | MAX   | 160  |
|                       |          |               | MIN       | 124    | MIN         | 126  | MIN   | 146  |
| Chloramines           | MG/L     | SM 4500-CL F  | AVG       | 2.72   | AVG         | 2.54 | AVG   | 2.71 |
|                       |          |               | MAX       | 2.95   | MAX         | 3.00 | MAX   | 3.00 |
|                       |          |               | MIN       | 2.30   | MIN         | 2.20 | MIN   | 2.40 |
| Sulfate               | MG/L     | SM 4500-SO4 E | AVG       | 31.0   | AVG         | 26.0 | AVG   | 35.0 |
|                       |          |               | MAX       | 31.3   | MAX         | 26.4 | MAX   | 35.4 |
|                       |          |               | MIN       | 30.8   | MIN         | 26.4 | MIN   | 35.4 |
| Total Organic Carbon  | MG/L     | SM 5310 C     | AVG       | 2.88   | AVG         | 2.67 | AVG   | 2.79 |
|                       |          |               | MAX       | 3.08   | MAX         | 2.80 | MAX   | 2.88 |
|                       |          |               | MIN       | 2.56   | MIN         | 2.52 | MIN   | 2.70 |
| Conductivity          | UMHOS/cm | SM 2510 B     | AVG       | 266    | AVG         | 267  | AVG   | 300  |
|                       |          |               | MAX       | 271    | MAX         | 267  | MAX   | 300  |
|                       |          |               | MIN       | 261    | MIN         | 267  | MIN   | 300  |
| Total Trihalomethanes | UG/L     | EPA 524.3 THM | AVG       | 34     | AVG         | 36.2 | AVG   | 32.7 |
|                       |          |               | MAX       | 38.6   | MAX         | 41.5 | MAX   | 33.2 |
|                       |          |               | MIN       | 30.2   | MIN         | 32.6 | MIN   | 32.2 |
| Turbidity             | NTU      | SM 2130 B     | AVG       | 0.05   | AVG         | 0.02 | AVG   | 0.05 |
|                       |          |               | MAX       | 0.09   | MAX         | 0.06 | MAX   | 0.06 |
|                       |          |               | MIN       | 0.02   | MIN         | 0.02 | MIN   | 0.03 |