

Draft Drinking Water Quality Report  
Date Range: 01-MAY-2017 to 31-MAY-2017

Parameter	Units	Method Cd		Davis WTP T2,T2H		Ullrich WTP T3		WTP 4 T4
-----	----	-----		-----		-----		-----
pH	SU	SM 4500-H B	AVG	9.6	AVG	9.6	AVG	9.6
			MAX	9.8	MAX	9.8	MAX	9.7
			MIN	9.5	MIN	9.4	MIN	9.5
Total Alkalinity	MG/L	SM 2320 B	AVG	60	AVG	59	AVG	66
			MAX	64	MAX	67	MAX	71
			MIN	54	MIN	55	MIN	62
Total Hardness	MG/L	SM 2340 C	AVG	84	AVG	84	AVG	86
			MAX	92	MAX	92	MAX	93
			MIN	77	MIN	80	MIN	81
Total Solids	MG/L	SM 2540 B	AVG	136	AVG	143	AVG	147
			MAX	168	MAX	150	MAX	158
			MIN	104	MIN	134	MIN	134
Chloramines	MG/L	SM 4500-CL F	AVG	2.65	AVG	2.51	AVG	2.55
			MAX	3.00	MAX	2.95	MAX	2.80
			MIN	2.50	MIN	2.18	MIN	2.38
Sulfate	MG/L	SM 4500-SO4 E	AVG	33.0	AVG	28.0	AVG	25.0
			MAX	33.8	MAX	27.8	MAX	24.9
			MIN	32.7	MIN	27.8	MIN	24.9
Total Organic Carbon	MG/L	SM 5310 C	AVG	2.88	AVG	2.68	AVG	2.76
			MAX	3.09	MAX	2.79	MAX	2.88
			MIN	2.63	MIN	2.50	MIN	2.64
Conductivity	UMHOS/cm	SM 2510 B	AVG	282	AVG	280	AVG	304
			MAX	282	MAX	280	MAX	304
			MIN	281	MIN	280	MIN	304
*Total Trihalomethanes	UG/L	EPA 524.2 & 524.3 THM	AVG	18.0	AVG	35.0	AVG	28.4
			MAX	21.7	MAX	36.0	MAX	28.6
			MIN	14.7	MIN	34.0	MIN	28.2
Turbidity	NTU	SM 2130 B	AVG	0.06	AVG	0.03	AVG	0.04
			MAX	0.11	MAX	0.05	MAX	0.06
			MIN	0.03	MIN	0.02	MIN	0.02

\*THM results do not include all data points for the month. Please check back for updated results.